



# Certificate of Compliance

**Certificate:** 2357666 (LR 57020-120)

**Master Contract:** 152235

**Project:** 2357666

**Date Issued:** December 14, 2010

**Issued to:** Magnetrol International Inc.

5300 Belmont Rd  
Downers Grove, IL 60515  
USA  
Attention: Paul Snider

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



*David Wood*

**Issued by:** David Wood

## **PRODUCTS**

**CLASS 2258 02** - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

**CLASS 2258 82** - PROCESS CONTROL EQUIPMENT - For Hazardous Locations -  
Certified to US Standards

Class I, Division 2, Groups A, B, C and D; Class II, Division 1 and 2, Groups E, F and G; Type 4X

SOLITEL vibrating rod level switching, rated 120Vac, 240Vac, 24Vac, 24Vdc, 3VA max

## **APPLICABLE REQUIREMENTS**

C22.2 No. 25-1966	Enclosures for Use in Class II, Groups E, F and G Hazardous Locations (Reaffirmed 2009)
C22.2 No. 142-M1987	Process Control Equipment
C22.2 No. 213-M1987	Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations
UL No 916 4th Edition	Energy Management Equipment
UL No. 1604 3rd Edition	Electrical Equipment for Use in Class I and II, Division 2, Class III Hazardous (Classified) Locations