



# Certificate / Certificat Zertifikat / 合格証

MAG 15-02-050 C001

*exida* hereby confirms that the:

## E3 Modulelevel Level Displacer Transmitter

**Magnetrol International, Inc.**

**Aurora, IL - USA**

The manufacturer  
may use the mark:



Revision 1.1 Sep 1, 2016  
Surveillance Audit Due  
September 1, 2019

Has been assessed per the relevant requirements of:

**IEC 61508 : 2010 Parts 1-7**

and meets requirements providing a level of integrity to:

**Systematic Capability: SC 3 (SIL 3 Capable)**

**Random Capability: Type B Element**

**SIL 2 @ HFT=0; SIL 3 @ HFT = 1; Route 2<sub>H</sub>**

**PFD<sub>AVG</sub> and Architecture Constraints  
must be verified for each application**

Safety Function:

The E3 Modulelevel Level Displacer Transmitter will measure a level, interface level or density measurement, and transmit a corresponding signal within the stated safety accuracy.

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.



ANSI Accredited Program  
PRODUCT CERTIFICATION  
#1004



Evaluating Assessor

  
Certifying Assessor

**Systematic Capability: SC 3 (SIL 3 Capable)**

**Random Capability: Type B Element**

**SIL 2 @ HFT=0; SIL 3 @ HFT = 1; Route 2<sub>H</sub>**

**PFD<sub>AVG</sub> and Architecture Constraints must be verified for each application**

E3 Module Level Level  
Displacer Transmitter

**Systematic Capability :**

The product has met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated. This device meets exida criteria for Route 2H.

**Random Capability:**

The SIL limit imposed by the Architectural Constraints must be met for each element.

**IEC 61508 Failure Rates in FIT\***

Device	$\lambda_{SD}$	$\lambda_{SU}$	$\lambda_{DD}$	$\lambda_{DU}$
E3 Local	0	13	579	61
E3 Remote	0	14	607	61

\* FIT = 1 failure / 10<sup>9</sup> hours

**SIL Verification:**

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFD<sub>AVG</sub> considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

**Assessment Report:** MAG 15-02-050 R002 V1 R2

**Safety Manual:** E3 Module Level Safety Manual 48-651.0



80 N Main St  
Sellersville, PA 18960